

Trim or Replace Impellers on Oversized Pumps

Suggested Actions

Consider impeller trimming when any of the following apply:

- The head provided by an oversized, throttled pump exceeds process requirements.
- System bypass valves are open, indicating excess flow rate.
- The pump is operating far from its design point.
- The operating head and (or) flow rate are greater than process requirements.

As a result of conservative engineering practices, pumps are often substantially larger than they need to be for an industrial plant's process requirements. Centrifugal pumps can often be oversized because of "rounding up," trying to accommodate gradual increases in pipe surface roughness and flow resistance over time, or anticipating future plant capacity expansions. In addition, the plant's pumping requirements might not have been clearly defined during the design phase.

Because of this conservative approach, pumps can have operating points completely different from their design points. The pump head is often less than expected, while the flow rate is greater. This can cause cavitation and waste energy as the flow rate typically must be regulated with bypass or throttle control.

Oversized and throttled pumps that produce excess pressure are excellent candidates for impeller replacement or "trimming," to save energy and reduce costs. Trimming involves machining the impeller to reduce its diameter. Trimming should be limited to about 75% of a pump's maximum impeller diameter, because excessive trimming can result in a mismatched impeller and casing. As the impeller diameter decreases, added clearance between the impeller and the fixed pump casing increases internal flow recirculation, causes head loss, and lowers pumping efficiency.

For manufacturing standardization purposes, pump casings and shafts are designed to accommodate impellers in a range of sizes. Many pump manufacturers provide pump performance curves that indicate how various models will perform

with different impeller diameters or trims. The impeller should not be trimmed any smaller than the minimum diameter shown on the curve.

Net positive suction head requirements (NPSHR) usually decrease at lower flow rates and can increase at the higher end of the pump head curve. The NPSHR at a given rate of flow will normally be greater with a smaller diameter impeller, but engineers should consult with the pump manufacturer to determine variations in NPSHR before trimming the impeller. Manufacturers can often provide trim correction charts based on historical test data.

How Impeller Trimming Works

Trimming reduces the impeller's tip speed, which in turn reduces the amount of energy imparted to the pumped fluid; as a result, the pump's flow rate and pressure both decrease. A smaller or trimmed impeller can thus be used efficiently in applications in which the current impeller is producing excessive head. Pump and system curves can provide the efficiency or shaft power for a trimmed impeller. If these curves are not available, affinity laws can be used to predict the variations in pumping performance with changes in the impeller diameter:

$$\begin{aligned} Q_2 / Q_1 &= D_2 / D_1 \\ H_2 / H_1 &= (D_2 / D_1)^2 \\ bhp_2 / bhp_1 &= (H_2 Q_2) / (H_1 Q_1) \\ &= (D_2 / D_1)^3 \end{aligned}$$

where

- Q = pump flow rate, in gallons per minute (gpm)
- H = head, in feet (H₁ is head for the original impeller; H₂, for a trimmed impeller)
- bhp = brake horsepower
- D = impeller diameter, in inches.

In practice, impeller trimming is typically used to avoid throttling losses associated with control valves, and the system flow rate will not be affected.

Note that, in contrast to centrifugal pumps, the operating regions of mixed-flow and axial-flow pumps are limited because of flow rate instabilities. Therefore, consult with the pump manufacturer before changing the impeller diameter. Removing stages is often advisable for a multi-stage centrifugal pump that is oversized for current operating conditions.

When a pump serves a critically important process, it might not be possible to wait for the impeller to be trimmed. In that case, consider ordering another impeller and continuing operation until the new resized impeller can be installed.

Example

A double-suction centrifugal pump equipped with an impeller 14 inches in diameter is throttled to provide a process cooling water flow rate of 3,000 gpm. The pumping system operates for 8,000 hours per year with a head of 165 feet (ft) and pump efficiency (η) of 80%. The pump

requires 156 bhp. Pump and system curves indicate that a trimmed impeller can supply the 3,000-gpm required flow rate at a head of 125 ft. From the affinity laws, the diameter of the trimmed impeller is approximately as follows:

$$(H_2Q_2) / (H_1Q_1) = (D_2 / D_1)^3$$

Holding Q constant,

$$\begin{aligned} D_2 &= D_1 \times (H_2 / H_1)^{1/3} \\ &= 14 \times (125 / 165)^{1/3} \\ &= 12.76 \text{ inches} \end{aligned}$$

Assuming that the pump efficiency remains unchanged, installing a 12^{3/4}-inch trimmed impeller reduces input power requirement to the following:

$$\begin{aligned} \text{bhp}_2 &= (H_2 \times Q_2) / (3,960 \times \eta) \\ &= (125 \times 3,000) / (3,960 \times 0.8) \\ &= 118.4 \text{ bhp} \end{aligned}$$

Estimated energy savings, assuming a 94% motor efficiency, are as follows:

$$(\text{bhp}_1 - \text{bhp}_2) \times 0.746 \text{ kW/hp} \times 8,000 \text{ hours/year} / 0.94 = 238,720 \text{ kWh/year}$$

At an electricity cost of 5 cents per kWh, total cost savings are estimated to be \$11,936 per year.

References

Match Pumps to System Requirements, U.S. Department of Energy Pumping Systems Tip Sheet #6, 2005.

Hydraulic Institute (HI).

Hydraulic Institute, the largest association of pump producers in North America, serves member companies and pump users worldwide by developing comprehensive industry standards, expanding knowledge by providing education and training, and serving as a forum for the exchange of industry information. In addition to the ANSI/HI pump standards, HI has a variety of resources for pump users and specifiers, including Pump LCC and VSP guidebooks, "7 Ways To Save Energy" training program and more. To download FREE executive summaries of HI's "Pump Life Cycle Costs", "Variable Speed Pumping", and an index to ANSI/HI Standards, visit www.Pumps.org and www.PumpLearning.org.



Pump Systems Matter™ (PSM).

Developed by the Hydraulic Institute, PSM is an educational initiative created to assist North American pump users gain a more competitive business advantage through strategic, broad-based energy management and pump system performance optimization. PSM's mission is to provide end-users, engineering consultants and pump suppliers with tools and collaborative opportunities to integrate pump system performance optimization and efficient energy management practices into normal business operations.



PSM is seeking the active support and involvement of energy efficiency organizations, utilities, pump users, consulting engineering firms, government agencies, and other associations. For more information on PSM, to become a sponsor, or to download PSM's *FREE Pump System Improvement Modeling Tool™* (PSIM), an educational tool designed to show pump systems engineers how modeling tools can reduce cost and conserve energy, visit www.PumpSystemsMatter.org.

U.S. Department of Energy (DOE).

DOE's Industrial Technologies Program (ITP), through partnerships with industry, government, and non-governmental organizations, develops and delivers advanced energy efficiency, renewable energy, and pollution prevention technologies for industrial applications. ITP has launched the **Save Energy Now** initiative to help the nation's manufacturing facilities continue to thrive during a time of diminished energy supplies and rising costs. As a part of this initiative, ITP is sending DOE Energy Experts to the nation's most energy-intensive manufacturing facilities to conduct 200 Energy Savings Assessments. See www.eere.energy.gov/industry for additional information on DOE's energy efficiency activities.



BestPractices emphasizes opportunities for savings in plant systems such as motor, steam, compressed air, and process heating systems. BestPractices is a part of the Industrial Technologies Program, and offers a variety of resources addressing ways to reduce energy and maintenance costs in industrial process systems. This includes training workshops, software tools, a series of sourcebooks, case studies, tip sheets, and other materials, including several which focus on opportunities in pumping systems. For example, the Pumping System Assessment Tool (PSAT) aids in the assessment of pumping system efficiency and estimating energy and cost savings.

For more information, please contact: EERE Information Center; 1-877-EERE-INF (1-877-337-3463); www.eere.energy.gov/industry/bestpractices.